

Summary of Decisions of the Structural Engineering Committee  
SEC 13/2011 held on 27.10.2011

(a) Case 13/2011

- Issue: To accept modified steel H-pile, formed by the welding of two steel plates to the flanges of steel H-pile, socketed into rock as a piling system
- Recommendation To accept a modified steel H-pile, formed by welding two 245mm x 30.4mm(t) Grade 450J0 steel plates to a 305x305x223 kg/m Grade 450J0 steel H-pile, socketed into rock as a piling system (Modified Socketed Steel H-pile).
- Decision: (a) Finding RSE's justification insufficient, members did not endorse the recommendation.