

Summary of Decisions of the Structural Engineering Committee  
SEC 01/2012 held on 18.01.2012

(a) Case 01/2012

Issue: Titanium Inserts Connections in Glass Wall

Recommendation: That connections consist of titanium inserts bonded by SentryGlas® Plus (SGP) for transferring wind load from facial glass panels to glass fin supports in a SGP laminated glass wall system at the G/F shop front be accepted.

Decision: Noting RSE's justifications and after making reference to previous cases, members endorsed the recommendations.