

Summary of Decisions of the Structural Engineer
SEC HD-01/2013 held on 9.1.2013

(a) Case HD-01/2013

- Issue: The use of Ground Granulated Blastfurnace Slag (GGBS) to partially replace cement in C40 concrete for pile caps
- Recommendation: The use of Ground Granulated Blastfurnace Slag (GGBS) to partially replace cement, at a proportion of 60% of the total cementitious content by mass, in C40 concrete for the construction of pile caps of the domestic blocks in the Housing Authority's (HA) public housing project
- Decision: Noting the project SSE of the HD's justifications and the quality assurance/monitoring measures to be implemented, members endorsed the recommendation.