

Summary of Decisions of the Structural Engineer
SEC 02/2013 held on 9.1.2013

(a) Case 02/2013

Issue: To accept the use of Ground Granulated Blastfurnace Slag to partially replace cement in grade C45 concrete

Recommendation: To accept the use of Ground Granulated Blastfurnace Slag (GGBS) to partially replace Portland cement, at a maximum proportion of 50% by mass of the total cementitious content, in grade C45 concrete for the construction of the superstructure of the proposed development.

Decision: Noting RSE's justifications and the quality assurance/monitoring measures to be implemented, members endorsed the recommendation.