

Summary of Decisions of the Structural Engineer  
SEC 4/2014 held on 22.1.2014

(a) Case 4/2014

Issue: Methodology Report for Wind Tunnel Test

Recommendation: To accept the following methodology and parameters proposed for wind tunnel test of the proposed development:

- (1) Topographic Model  
Model scale: 1: 4000
- (2) Proximity Model
  - (i) Model scale: 1: 400
  - (ii) Extent of model: all known existing and proposed surrounding buildings and structures within a radius of 500 m from the subject site will be modeled.
- (3) Wind Climate Study Results  
Directional characteristics of typhoons affecting HK based on a Monte Carlo simulation of storms passing within 250km of HK.
- (4) Possible removal of adjacent buildings that could provide significant shelter  
Twenty-eight building groups were proposed to be removed in the Proximity Model.

Decision: Having noted the background information and arguments, members endorsed the recommendation subject to refinement in the determination of the buildings to be removed in the Proximity Model.