

Summary of Decisions of the Structural Engineering Committee
SEC Meeting 2/2017 held on 15.5.2017

Case 5/2017

- Issue: Use of Laminated Glass with SentryGlas® Plus (SGP) Interlayers in Glass Wall Works
- Recommendation: To accept the structural use of laminated glass panels, bonded by SentryGlas® Plus (SGP) interlayers, designed to act compositely with the degree of composite action limited to 70% of the structural stiffness of an equivalent monolithic glass pane of thickness equals to the sum of thickness of the individual glass panes excluding the thickness of the interlayers in the proposed laminated glass panels.
- Decision: Noting the justifications provided are insufficient, members did not endorse the recommendation.