## Case 12/2017

Issue:	Methodology Report for Wind Tunnel Test	
Recommendation:	To accept the following methodology and parameters for wind tunnel test at the proposed development:	
	(1)	Topographic Model
		Model scale: 1: 4,000
	(2)	Proximity Model
		(i) Model scale: 1: 400
		<ul><li>(ii) Extent of model: all known existing and proposed surrounding buildings and structures within a radius of 500m from the subject site will be modeled.</li></ul>
	(3)	Wind Climate Study Results
		Directional characteristics of typhoons affecting HK based on a Monte Carlo simulation of storms passing within 250km of HK, conducted by Applied Research Associates, Inc. (ARA).
	(4)	Removal of adjacent buildings that could provide significant shelter
		27 building groups were proposed to be removed in the Proximity Model.
	(5)	Design Wind Loads Adopted in Superstructure Design
		The following in the superstructure design were proposed:
		<ul> <li>(i) The finally adopted peak design combined wind moment will not be less than 70% of the peak design wind moment based on code calculation as derived from the design values given in the Code of Practice on Wind Effects in Hong Kong 2004 (the Wind Code);</li> </ul>
		(ii) If the peak design combined wind moment determined in the wind tunnel test is found greater than the peak design wind moment based on code calculation as derived from the design values given in the Wind Code, the peak design combined wind moment determined in

(iii) The storey wind shears adopted for design shall be determined from the peak design combined wind

the wind tunnel test will be adopted for design;

the peak design combined wind moment determined in

moment established in accordance with sub-paragraphs (i) and (ii) above; and

- (iv) The peak building acceleration assessment on human comfort under wind loads determined in the wind tunnel test shall be in accordance with the Code of Practice for Structural Use of Concrete 2013 clause 7.3.2. Limiting maximum peak acceleration at the top occupied floor of a residential building to 0.15m/s<sup>2</sup> should be adopted.
- Decision: Having noted the background information and arguments together with RSE's supervision arrangement, members endorsed the recommendation.